



Τεχνολογίες Ψύξης



Θάνος Δαζελίδης – Product manager Rittal





Cooling topologies

4 Basic Types


Scalable DC:	Low Density
Scalable DC:	Mid Density 1
Scalable DC:	Mid Density 2
Scalable DC:	High Density



Cooling topologies

Scalable DC: Low Density

Standard raised floor climatisation with downflow






Cooling topologies

Scalable DC: Mid Density 1

Standard raised floor climatisation with downflow and aisle containment






Cooling topologies

Scalable DC: Mid Density 2

Rowbased Cooling with:Aisle Containment and LCP Inline







Cooling topologies


Scalable DC: High Density

Rackbased Cooling with LCP





Perfect fit into The System Complementary Technology






Best practices in cooling



Best practices in cooling



Old technologies!!!





Best practices in cooling

Downflow units VS Traditional




Airside pressure drop reduced due to moving the fan into the raised floor:

Energy savings around: 15 to 47%



Best practices in cooling

EC-FANS VS Traditional



Usage of EC-type fans:

Electrical energy saving up to 24% per se



Best practices in cooling

Water Temperatures

With bigger HEX you can increase water inlet temperatures – this results in increased free-cooling performance.





Best practices in cooling

- **With conventional room climatisation (downflow) or in-line without containment**

Assumptions:

- 26kW of installed equipment
- Room dim 10x4x5 (width x depth x height)
- 8 racks 800x1000x42U
- 20 C inside temperature

Results :

- Required cooling of the equipment 24 kW
- Required cooling for the room with $\Delta T=15C$ (inner –outer temp difference) 10 kW
- Total required cooling capacity of units: 34 kW



Best practices in cooling


- **With Rack –based climatisation**

Assumptions:

- 26kW of installed equipment
- Room dim 10x4x5 (width x depth x height)
- 8 racks 800x1000x42U (dim 6.4 x 1 x 2)
- 21 C inside temperature

Results :

- Required cooling of the equipment 24 kW
- Required cooling for the racks with $\Delta T=5C$ (inner –outer temp difference) 3 kW
- Total required cooling capacity of units: 27 kW
- Energy saving 20- 25%





Ευχαριστούμε πολύ!!

